



Paramètre mesuré	Concentrations 2017									Norme
	24-févr		18-mai		21-juil		Amont Alsace	Rejet Alsace	Magenta	
	Magenta	Alsace	Magenta	Alsace	Magenta	Alsace				
DCO (mg d'O₂/l)	2519	364	1750	967	1080	512		1599	1060	2000
DBO₅ (mg d'O₂/l)	1520	140	1090	450	710	290		510	500	800
DCO/DBO₅	1.66	2.60	1.61	2.15	1.52	1.77	#DIV/0!	3.14	2.12	
MeS (mg/l)	142	123	38	215	173	145		260	143	600
NTK (mg/l)	339	34.8	231	80.4	158	40.7		113	136	
Azote global (mg/l)	339	35.28	231	83.04	158	40.7		115.75	136	150
Phosphore total (mg/l)	59.8	7	53.7	14.8	31	28.1		53.6	54.7	50
Chlorures (mg/l)	423	52	246	90.6	246	126		114	246	400
Matières grasses (mg/l)	17	17	21	28	1	15		16	1	100
pH	7.7	7.8	7.4	8.3	7.6	7.4		7		5,5<pH<8,5

